



AAMA 508-07 TEST REPORT

TESTING INFORMATION

REPORT NO.: A2100.01-602-44
TEST DATE: 06/30/2010
REPORT DATE: 07/29/2010

TESTING AGENCY INFORMATION

ARCHITECTURAL TESTING INC
5906 SAXON AVENUE
SCHOFIELD, WI 54476
PHONE: 715-241-8624
FAX: 715-241-8425
WWW.ARCHTEST.COM

TEST SPECIMEN DESCRIPTION:

SERIES/MODEL: OMNI RAIN SCREEN SYSTEM
PRODUCT TYPE: PRESSURE EQUALIZED RAIN SCREEN SYSTEM

OVERALL SIZE: 8'0"X7'11"
INDIVIDUAL PANEL SIZES: 3'11-3/4" X 3'11-1/4"
PANEL THICKNESS: 4MM
CAVITY TO VENT RATIO: 9.72FT³/0.006FT²
DRAINAGE: ¼" DIAMETER SLOTTED WEEP HOLES (2 PER PANEL)

Test Results: The temperature during testing was 67°F. The results are tabulated as follows:

Test Method	Title of Test	Results	Allowed
ASTM E 283	Air Infiltration 1.57 psf (25 mph)	0.61 L/s/m ² (0.12 cfm/ft ²)	(0.11 cfm/ft ² min) (0.13 cfm/ft ² max)
ASTM E 1233	Pressure Cycling 100 cycles from 5.0 psf to 25.0 psf	<0.01 sec. Pass	0.08 sec
ASTM E 331	Static Water Resistance 6.24 psf	3.17 ft ² Pass	3.2 ft ²
AAMA 501.1	Dynamic Water Resistance 6.24 psf	2.99 ft Pass	3.2 ft ²