



**AAMA 508-07 TEST REPORT**

**TESTING INFORMATION**

**REPORT NO.:** A2099.01-602-44  
**TEST DATE:** 06/29/2010  
**REPORT DATE:** 08/02/2010

**TESTING AGENCY INFORMATION**

**ARCHITECTURAL TESTING INC**  
5906 SAXON AVENUE  
SCHOFIELD, WI 54476  
PHONE: 715-241-8624  
FAX: 715-241-8425  
WWW.ARCHTEST.COM

**TEST SPECIMEN DESCRIPTION:**

**SERIES/MODEL:** OMNI WS™  
**PRODUCT TYPE:** ROUT & RETURN – WET SEAL SYSTEM

**OVERALL SIZE:** 8'0"X7'11"  
**INDIVIDUAL PANEL SIZES:** 3'11-3/4" X 3'11-1/4"  
**PANEL THICKNESS:** 4MM  
**CAVITY TO VENT RATIO:** 9.72FT<sup>3</sup>/0.006FT<sup>2</sup>

**Test Results:** The temperature during testing was 73°F. The results are tabulated as follows:

<b>Test Method</b>	<b>Title of Test</b>	<b>Results</b>
ASTM E 283	Air Infiltration 1.60 psf (25 mph) 6.27 psf (50 mph)	<0.01 cfinift <sup>2</sup> <0.01 cfinift <sup>2</sup>
ASTM E 331	Water Resistance 15.0 psf	No leakage
AAMA 501.1	Water Resistance 15.0 psf	No leakage

**General Note:** All testing was performed in accordance with the referenced standards.